Display energy certificate (DEC)



London School of Economics & Political Science Sardinia House 51-52 Lincoln's Inn Fields LONDON WC2A 3LZ Operational rating

Certificate number: 1754-7217-8912-6292-6002

Valid until: 18 January 2024


Total useful floor area: 2796 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.



This building's energy use		
Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	40.26	85.20
Typical energy use (kWh/m2/year)	118.4	251.08
Energy from renewables	0%	0%

Previous operational ratings	
Date	Operational rating
January 2023	34 B
January 2022	39 B
January 2021	60 C

Total balbon dioxide (OOZ) chilosions				
This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.				
Date	Electricity	Heating	Renewables	
January 2023	62	46	0	
January 2022	55	55	0	
January 2021	112	22	0	

Total carbon dioxide (CO2) emissions

Assessment details

Assessor's name	Martin Keane
Employer/Trading name	Low Carbon Europe Limited
Employer/Trading address	12a Marlborough Place, Brighton BN1 1WN
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	13 March 2023
Nominated date	19 January 2023