

Display energy certificate (DEC)

The London School of Economics and Political Science
 London School of Economics
 9-10 Sheffield Street
 London
 WC2A 2EY

Operational rating

C

Certificate number: 0278-9916-2552-4502-4802

Valid until: 14 January 2036

Total useful floor area: 421 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C	55 C	
76-100	D		
			100
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
January 2026	55 C
December 2015	71 C

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2026	20	0	0
December 2015	26	0	0

Assessment details

Assessor's name	Naveen Palaniappan
Employer/Trading name	Low Carbon Europe
Employer/Trading address	5th floor, 100-101 Queens Road, Brighton, East Sussex, BN1 3XF
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	6 February 2026
Nominated date	15 January 2026

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	84.87	0
Typical energy use (kWh/m ² /year)	80	214.12
Energy from renewables	0%	0%

